



NOTES:

1. EXISTING SERVICE PANEL SHALL REMAIN. FOR NEW OR UPGRADE SERVICE PANEL, APPLICANT MUST SEEK SPOT APPROVAL FROM AZUSA ELECTRIC DIVISION PRIOR TO INSTALLATION. INSTALL SERVICE PANEL AT UNAPPROVED SPOT COULD RESULT IN DELAY OF PROJECT UNTIL ALL CORRECTION IS MADE TO THE SATISFACTION OF THE ELECTRIC DIVISION. REFER TO AZUSA'S ELECTRIC STANDARD ED22 AND ED2 FOR REQUIREMENTS PERTAINING TO SERVICE PANEL INSTALLATION. SIZE ALL BRANCH CIRCUIT BREAKER PER LATEST NATIONAL ELECTRICAL CODE (N.E.C) EDITION CURRENTLY ENFORCED BY LOCAL AUTHORITY.
2. PRODUCTION METER SUPPLIED BY AZUSA LIGHT DIVISION. REFER TO EUSERC STANDARD FOR SOCKET TYPE.
3. AC DISCONNECT SHALL BE LOCKABLE IN OFF POSITION.
4. MAIN SERVICE , PRODUCTION METER SOCKET, AND AC DISCONNECT SHALL BE WITHIN 8 FEET OF EACH OTHER AND A MINIMUM 10" APART, LOCATED OUTDOOR, AND ACCESSIBLE TO THE UTILITY COMPANY AT ALL TIMES.
5. ALL INSTALLATIONS REQUIRE SEPARATE PERMIT, APPROVAL, AND INSPECTION FROM THE CITY'S BUILDING AND SAFETY DIVISION.



ELECTRIC STANDARD

DRAWN: HV

DATE: 2-5-13

SCALE: NTS

REQUIREMENTS FOR CUSTOMERS WITH PHOTOVOLTAIC GENERATOR

APPROVED: *Juan K. Leung* 2-26-13 **DATE**

DWG. NO.

ED25

SHEET

1 OF 1